

SUBMITTAL SHEET

Sheet No. 1 of 1
Date: 12/05/2020

SUBMITTAL No. 176

Revision No. 00

Response Required By: 15/05/2020

Material Code:

WS

B – Building

M – Mechanical

E – Electrical

WS – Water and Sewage

Tema:

Saglasnost na Izbor Materijala (MAF) :

Pumpa za povišenje pritiska u sanitarnoj mreži – poslovni deo

Description:

Material Approval Form:

/

Referentna dokumentacija:

BoQ WW-ViK 3/1.6.7. Г.19. - ВОДОВОД (САНИТАРНИ И ПРОТИВПОЖАРНИ)

Reference:

/

Prilozi / Enclosures:

- 1) TDS_Pumpa za povisenje pritiska - poslovni deo

☐ SHOP DRAWING

☐ CERTIFICATION/REPORT

☒ CATALOGUES/TDS

☐ METHOD STATEMENT

☐ MATERIAL SAMPLE

☐ GUARANTEE

☐ SKETCH DRAWING

☐ OTHER (Test Documents)

Napomena / Note:

/

Status prihvatanja / Acceptance of submitted item:

Datum / Date: 08.06.2020.

☐ APPROVED

☒ APPROVED WITH COMMENT

☐ REVISE AND RESUBMIT

☐ REJECTED

Komentar / Comment:

- Postrojenje za povišenje pritiska u sanitarnoj mreži – poslovni deo – II zona
(RADNA + REZ. PUMPA SA FREKV. REGULA Q=4,7 l/s, H=32,9m, N= 3KW (1+1)
- BOOSTING UNIT IN THE SANITARY NETWORK – BUSINESS SECTOR
(TWO PUMPS, WORKING AND SPARE, THE TWO FREQUENCY CONTROLLED, Q=4,7 l/s, H=32,9, N=3kw

Submittal primljen (Nadzorni organ) / Submittal received by (Engineer):

[Signature]

Datum / Date:

May 12th, 2020

Odgovor na Submittal primljen (Izvođač) / Submittal response received by (Contractor):

[Signature]

Datum / Date:

09/06/2020