

SUBMITTAL SHEET

Sheet No. 1 of 1
Date: 12/05/2020

SUBMITTAL No. 178

Revision No. 00

Response Required By: 15/05/2020

Material Code: WS

B – Building

M – Mechanical

E – Electrical

WS – Water and Sewage

Tema:

Saglasnost na Izbor Materijala (MAF) :

Pumpa za povišenje pritiska u hidrantskoj mreži

Description:

Material Approval Form:

/

Referentna dokumentacija:

BoQ WW-ViK 3/1.6.7. Г.21. - ВОДОВОД (САНИТАРНИ И ПРОТИВПОЖАРНИ)

Reference:

/

Prilozi / Enclosures:

- 1) TDS_Pumpa za povišenje pritiska - hidrantska

☐ SHOP DRAWING

☐ CERTIFICATION/REPORT

☒ CATALOGUES/TDS

☐ METHOD STATEMENT

☐ MATERIAL SAMPLE

☐ GUARANTEE

☐ SKETCH DRAWING

☐ OTHER (Tech. Documents)

Napomena / Note:

/

Status prihvatanja / Acceptance of submitted item:

Datum / Date: 08.06.2020.

☐ APPROVED

☒ APPROVED WITH COMMENT

☐ REVISE AND RESUBMIT

☐ REJECTED

Komentar / Comment:

- Postrojenje za povišenje pritiska u hidrantskoj mreži - II zona
(Radna + Rezervna)
- Boosting unit in hydrant network
(two pumps, working and spare)
 $Q = 7.5 \text{ l/s}$, $H = 40.3 \text{ m}$ $N = 55 \text{ kW}$
(karakteristike pojedinačne pumpe)

Submittal primljen (Nadzorni organ) / Submittal received by (Engineer):

[Signature]

Datum / Date:

May 12th / 2020

Odgovor na Submittal primljen (Izvođač) / Submittal response received by (Contractor):

[Signature]

Datum / Date:

09/06/2020